

Date: January 2, 2020

To: Plan Holders

Subject: Addendum No. 3 to the Bidding Documents for: ITB No. 2020-002

Security Camera, Detention Monitoring and Control Systems Upgrade at:

Champaign County Courthouse
101 East Main Street
Urbana, Illinois 61801

Juvenile Detention Center
400 Art Bartell Road
Urbana, Illinois 61802

Addendum No. 3 becomes a part of the bidding and contract documents and modifies the original bidding documents, dated December 4, 2019. Acknowledge receipt of Addendum No. 3 in the space provided on Bid Form. **FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.**

Addendum No. 2

1. Specification Section 00 1116 - Invitation to Bid
 - a. Item 1.a. - REVISE to "Thursday, January **30**, 2020".

Specifications

1. Specification Section 28 5211 - Detention Monitoring and Control System
 - a. Page 28 5211-18, Paragraph 2.9-B. - Add as follows:
 - B. A dedicated UPS unit shall be provided for all new electrified equipment at the Champaign County Courthouse with the exception of the new video surveillance rack in the main IT room (as this rack will be powered by the existing facility UPS). All loads at the Champaign County Juvenile Detention Center shall be powered by the facility's existing building-wide UPS.

Bids are due Thursday, January 30, 2020 at 2:00 p.m. central time at the Lyle Shields Conference Room, Brookens Administrative Center, 1776 East Washington, Urbana, Illinois.

Respectfully submitted,

GHR Engineers and Associates, Inc.

Lucas E. McGill, PE
Project Manager
Phone: 217-356-0536
Fax: 217-356-1092

LEM/smh

Addendum No. 3 - Security Camera Detention Monitoring and Control Systems Upgrade.wpd