

Date: January 24, 2020

To: Plan Holders

Subject: Addendum No. 4 to the Bidding Documents for: ITB No. 2020-002

Security Camera, Detention Monitoring and Control Systems Upgrade at:

Champaign County Courthouse
101 East Main Street
Urbana, Illinois 61801

Juvenile Detention Center
400 Art Bartell Road
Urbana, Illinois 61802

Addendum No. 4 becomes a part of the bidding and contract documents and modifies the original bidding documents, dated December 4, 2019. Acknowledge receipt of Addendum No. 4 in the space provided on Bid Form. **FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.**

Clarifications

1. Control system at Champaign County Courthouse shall provide control an monitoring of existing elevator #3 (four floors, stops at three floors) and existing elevator #4 (stops at all four floors).
2. Controls systems at Champaign County Courthouse and Juvenile Detention Center shall have entirely separate head ends.
3. System integrator shall provide ample time to sit with owner and ensure control system meets the functional needs of the facility (door interlocks, etc.).

Specifications

1. Section 28 5211 - Detention Monitoring and Control System
 - a. Page 28 5211-5, Paragraph 1.8-B.4. - Add as follows:
 4. Siemens.

Bids are due Thursday, January 30, 2020 at 2:00 p.m. central time at the Lyle Shields Conference Room, Brookens Administrative Center, 1776 East Washington, Urbana, Illinois.

Respectfully submitted,

GHR Engineers and Associates, Inc.

Lucas E. McGill, PE
Project Manager
Phone: 217-356-0536
Fax: 217-356-1092

LEM/smh

Addendum No. 4 - Security Camera Detention Monitoring and Control Systems Upgrade.wpd